



# MUNICIPAL CORPORATION CHANDIGARH

Public Health Laboratory at Water Works Sector - 39

## TEST - REPORT

Not for legal use

Ref. No. & Date :- No.GMSSS/Maloya/2024-25/565 dated: 25.03.2025  
Issued to :- The Incharge  
:- Govt Model Sr. Sec. School  
:- Village - Maloya, Chandigarh  
Quantity of sample :- Approximate 1200 ml.  
Date of Collection :- 28-03-2025  
Client reference :- Sample Collected by Laboratory Staff  
Packing of sample :- Sample filled in P.P. and Glass Bottle  
Source of sample :- from School tap of Govt Model Sr. Sec. School  
Village - Maloya, Chandigarh


S.No.	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	----	7.58
2	Odour	Agreeable	----	Agreeable
3	Taste	Agreeable	----	Agreeable
4	Turbidity	< 1.0	N.T.U.	0.5
5	Residual Chlorine	0.2 - 0.4	mg/l	0.2
6	Total Alkalinity (as CaCO <sub>3</sub> )	< 200	mg/l	232
7	Total Hardness (as CaCO <sub>3</sub> )	< 200	mg/l	120
8	Chloride (as Cl)	< 250	mg/l	07
9	Free & Saline Ammonia	NIL	mg/l	NIL
10	Total Dissolved Solids	< 500	mg/l	258
11	M.P.N. of Coliform Bacilli Per 100ml of water	Zero	M.P.N.	0 (Excellent)


Payment received videreceipt No.03/2024-25/240319, dated 25.03.2025, Amount Rs.3300/-

**Note: Water is fit for drinking.**

Lab No.- MCPHL/25/ ..1031.....

Dated:- 01.04.2025


  
Chemist  
M.C.P.H. Laboratory  
Chandigarh


  
Sub Divisional Engineer,  
M.C.P.H. Sub Division No.1  
Chandigarh

Dated :-01.04.2025

Endst No. MCPH/25/.....

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh  
For Information Please.

  
Chemist  
M.C.P.H. Laboratory  
Chandigarh

  
Sub Divisional Engineer,  
M.C.P.H. Sub Division No.1  
Chandigarh